

DEPARTMENT OF ENVIRONMENTAL PROTECTION & SUSTAINABILITY

Interoffice Memo

TO: Sheldon E. Epstein, Chief
Bureau of Engineering and Construction, Storm Drain Design Section
Department of Public Works

FROM: Kritty Udhin, P.E., Manager /signed/
Stormwater Management
Department of Environmental Protection and Sustainability

DATE: November 22, 2019

SUBJECT: Kingston Road Drainage Improvements
Stormwater Management Variance
Back River Watershed
EPS Project ID: M190317
Tracking Number: 05-19-3106

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the installation of storm drain segments, inlets, manholes and the relocation of an existing water main line by cut and cover. The existing cover conditions will be re-established once the project is completed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area as a result of this project.

Please contact Andrew Fish, P.E. of my staff at 410-887-3768 should you have any questions.

KU:jcm

c : Andrew Fish, P.E.

variance approval letter